



Pipe Size, Inches	Maximum Distance Between Supports Center to Center Feet
6	15
8	17
10	18
12	20
14	21
16	23
18	24
20	26
24	27
30	30
36	32
42	32
48	32
54	32
60	32
64	32

TYPICAL AERIAL GRAVITY SANITARY SEWER

- NOTE: 1. Nearest External Flange Face shall be 9" Minimum from Pipe Support
2. A Flood Plain Development Permit will be required from the City of Ponca City Engineering Department. Compensatory storage shall also be required.
3. A 404 Permit from the Corps' of Engineers will be required for crossing the Arkansas River, or other navigable streams.



**AERIAL GRAVITY
SANITARY SEWER STREAM CROSSING STANDARD**

THE CITY OF
PONCA CITY, OKLAHOMA

CITY ENGINEERING DEPT. * 516 E. GRAND * P. O. BOX 1450 * PONCA CITY, OK. * (580)767-0326, FAX-0325

Designed by MIKE CHAPMAN	Checked by JIM FAIRBANKS & DARVIN HANEY
Drawn by SIMON CORNELL	Revised by
Project No.	Date: Oct. 2008 SEWSTD 190

NOT TO SCALE